

## EXPERIMENTAL HEAT TRANSFER ANALYSIS OF THE IPR-R1 TRIGA REACTOR

Amir Zacarias Mesquita<sup>1</sup> and Hugo César Rezende<sup>2</sup>

Centro de Desenvolvimento da Tecnologia Nuclear  
<sup>1</sup> Serviço de Reator e Irradiações  
<sup>2</sup> Serviço de Engenharia de Reatores e Sistemas  
Campus da UFMG - Pampulha – Caixa Postal 941  
30123-970, Belo Horizonte, MG, Brazil.  
[amir@cdtn.br](mailto:amir@cdtn.br), [hcr@cdtn.br](mailto:hcr@cdtn.br)

### ABSTRACT

The heat generated by nuclear fission is transferred from fuel elements to the cooling system through the fuel-to-cladding gap and the cladding to coolant interfaces. The fuel thermal conductivity and the heat transfer coefficient from the cladding to the coolant were evaluated experimentally. A correlation for the gap conductance between the fuel and the cladding was also presented. As the reactor core power increases, the heat transfer regime from the fuel cladding to the coolant changes from single-phase natural convection to subcooled nucleate boiling. Results indicated that subcooled boiling occurs at the cladding surface in the central channels of the reactor core at power levels above approximately 60 kW.

### 1. INTRODUCTION

The IPR-R1 TRIGA Nuclear Research Reactor (Fig. 1), installed at Nuclear Technology Development Center (CDTN), is a pool type reactor cooled by natural circulation, and having as fuel an alloy of zirconium hydride and uranium enriched at 20% in <sup>235</sup>U. The core contains 59 aluminum-clad fuel elements and 5 stainless steel-clad fuel elements. One of these steel-clad fuel elements is instrumented in the center with three thermocouples (Fig. 1).




Figure 1. Core upper view with the instrumented fuel element in ring B and instrumented fuel element scheme

The heat generated by fissions is transferred from fuel elements to the cooling system through a fuel-to-cladding interface and from cladding to coolant. The objective of the thermal and hydrodynamic projects of the reactors is to remove the heat safely, without producing excessive temperature in the fuel elements. The regions of the reactor core where boiling occurs at various power levels can be determined from the heat transfer coefficient data.

The thermal conductivity ( $k$ ) of the metallic alloys is mainly a function of temperature. In nuclear fuels, this relationship is more complicated because  $k$  also becomes a function of irradiation as a result of change in the chemical and physical composition (porosity changes due to temperature and fission products). Many factors affect the fuel thermal conductivity. The major factors are temperature, porosity, oxygen to metal atom ratio, PuO<sub>2</sub> content, pellet cracking, and burnup. The second largest resistance to heat conduction in the fuel rod is due to the gap. Several correlations exist [1] to evaluate its value in power reactors fuels, which use mainly uranium oxide. The only reference found to TRIGA reactors fuel is General Atomic [2] that recommends the use of three hypotheses for the heat transfer coefficient in the gap. The heat transfer coefficient ( $h$ ) is a property not only of the system but also depends on the fluid properties. The determination of  $h$  is a complex process that depends on the thermal conductivity, density, viscosity, velocity, dimensions and specific heat. All these parameters are temperature-dependent and change when heat is being transferred from the heated wall to the fluid. An operational computer program and a data acquisition and signal processing system were developed as part of this research project [9] to allow on line monitoring of the operational parameters.

## 1. OVERALL THERMAL CONDUCTIVITY OF THE FUEL ELEMENTS

From Fourier equation described in [5, 6], it was obtained the expression of overall thermal conductivity ( $k_g$ ), in [W/mK], for cylindrical fuel elements

$$k_g = \frac{q''' r^2}{4(T_o - T_{sur})} \quad , \quad (1)$$

where  $q'''$  is the volumetric rate of heat generation [W/m<sup>3</sup>],  $T_o$  and  $T_{sur}$  are the fuel central temperature and the surface temperature [°C] and  $r$  is the fuel element radius [m].

The temperature at the center of the fuel was measured. The heat transfer regime at the power of 265 kW in all fuel elements is the subcooled nucleate boiling. The cladding outside temperature is the water saturation temperature ( $T_{sat}$ ) at the pressure of 1.5 bar (atmospheric pressure added up of the water column of ~ 5.2 m), increased of the wall superheat ( $\Delta T_{sat}$ ). The superficial temperature ( $T_{sur}$ ) in [°C] is found using the expression below, where  $T_{sat}$  is equal to 111.37 °C [7].

$$T_{sur} = T_{sat} + \Delta T_{sat} \quad . \quad (2)$$

The wall superheat is obtained by using the correlation proposed by McAdams found in [8],

$$\Delta T_{sat} = 0.8I(q'')^{0.259} \quad , \quad (3)$$

with  $q''$  in [W/m<sup>2</sup>] and  $T_{sat}$  in [°C].

A fuel element instrumented with three type K thermocouples was introduced into position B1 as shown in Fig. 1. Two thermocouples were also placed in two core channels adjacent to position B1.

## 2. HEAT TRANSFER IN THE REACTOR CORE


### Single-Phase Region

The heat transfer coefficient in single-phase region ( $h_{sp}$ ) was calculated with the Dittus-Boelter correlation described in [10], valid for turbulent flow in narrow channels, given for:

$$h_{sp} = 0.023 \frac{k}{D_w} \left( \frac{GD_w}{\mu} \right)^{0.8} \left( \frac{c_p \mu}{k} \right)^{0.4}, \quad (4)$$

where  $D_w = 4A/P_w$  is the hydraulic diameter of the channel based on the wetted perimeter;  $A$  is the flow area [m<sup>2</sup>];  $P_w$  is the wetted perimeter [m];  $G$  is the mass flow [kg/m<sup>2</sup>s];  $c_p$  is the isobaric specific heat [J/kgK];  $k$  is the thermal conductivity [W/mK]; and,  $\mu$  is the fluid dynamic viscosity [kg/ms]. The fluid properties for the IPR-R1 TRIGA core are calculated for the bulk water temperature at 1.5 bar.

The two hottest channels in the core are Channel 0 and Channel 1' (Fig. 2). The heat transfer coefficient was estimated using the Dittus-Boelter correlation. The inlet and outlet temperatures in Channel 0 were considered as being the as in Channel 1'. Table 1 gives the geometric data of Channel 0 and Channel 1' and the percent contribution of each fuel element to the channel power. The curves of single-phase heat transfer, as function of  $\Delta T_{sat}$ , are presented in the Fig. 2.



**Figure 2. The two hottest channels in the core and heat-transfer regimes in the fuel element surface**

The mass flow rate is given indirectly from the thermal balance along the channel using measurements of the water inlet and outlet temperatures:

$$q = \dot{m} c_p \Delta T, \quad (5)$$

where  $q$  is the power supplied to the channel [kW];  $\dot{m}$  is the mass flow rate in the channel [kg/s];  $c_p$  is the isobaric specific heat of the water [J/kgK]; and,  $\Delta T$  is the temperature difference along the channel [°C].

**Table 1. Channel 0 and Channel 1' Characteristics [9]**

	<b>Channel 0</b>	<b>Channel 1'</b>	<b>Unit</b>
Area ( A )	1.574	8.214	cm <sup>2</sup>
Wetted Perimeter ( P <sub>w</sub> )	5.901	17.643	cm
Heated Perimeter ( P <sub>h</sub> )	3.906	15.156	cm
Hydraulic Diameter ( D <sub>w</sub> )	1.067	1.862	cm
B1 and C1 Fuel Diameter (stainless)	3.76	3.76	cm
B6 and C12 Fuel Diameter (Al)	3.73	3.73	cm
C1 Control Rod Diameter	3.80	3.80	cm
Central Thimble	3.81	3,81	cm
Core Total Power (265 kW)	100	100	%
B1 Fuel Contribution	0.54	1.11	%
B6 Fuel Contribution	0.46	0.94	%
C11 Fuel Contribution	-	0.57	%
C12 Fuel Contribution	-	1.08	%
Total Power of the Channel	1.00	3.70	%

The reactor was operated on steps of about 50 kW until 265 kW and data were collected in function of the power supplied to Channel 1' and Channel 0. The values of the water thermodynamic properties at the pressure 1.5 bar as function of the bulk water temperature at the channel were taken from Wagner and Kruse [7]. The curve for heat transfer coefficient ( $h_{sur}$ ) in the single-phase region is shown in Fig. 3 as function of the power.

### **Subcooled Nucleate Boiling Region**


For the subcooled nucleated boiling region (local or surface boiling), the expression used is shown below, according to [11, 12]:

$$h_{sur} = q'' / \Delta T_{sat} \quad , \quad (6)$$

where  $h_{sur}$  is the convective heat-transfer coefficient from the fuel cladding outer surface to the water [kW/m<sup>2</sup>K];  $q''$  is the fuel surface heat flux [kW/m<sup>2</sup>]; and,  $\Delta T_{sat}$  is the surface superheat in contact with the water [°C].

Figure 2 presents the fuel element surface heat transfer coefficient for the coolant as a function of the superheat, in both regimes. This curve is specific for the IPR-R1 TRIGA reactor conditions. The correlation used for the subcooled nucleate boiling is not valid for single-phase convection region, as well as the Dittus-Boelter correlation is not valid for the boiling region. The transition point between single-phase convection regime to subcooled nucleate boiling regime (onset of nucleate boiling) is approximately 60 kW as shown in the graph.

Figure 3 presents the curves for the heat transfer coefficient ( $h_{sur}$ ) on the fuel element surface and for the overall thermal conductivity ( $k_g$ ) in fuel element as function of the power, obtained for the instrumented fuel at core position B1.



**Figure 3. Overall fuel element thermal conductivity and cladding heat transfer coefficient to the coolant**

### 3. HEAT TRANSFER COEFFICIENT IN THE FUEL GAP

The instrumented fuel element is composed of a central zirconium filler rod with 6.25 mm in diameter, the active part of the fuel, formed by uranium zirconium hydride alloy (U-ZrH<sub>1.6</sub>), an interface (gap) between the fuel and the cladding, and the 304 stainless steel cladding. The thermocouples are fixed in the central rod. It is assumed that all heat flux is in the radial direction. Using the analogy with electric circuits, the resistance to the heat conduction from the fuel center to the coolant ( $R_g$ ) is given by the sum of the fuel components resistances.

The fuel element configuration is shown in Fig. 4. The axial heat conduction and the presence of the central pin of zirconium were not considered. The thermal conductivity of the U-ZrH<sub>1.6</sub> fuel is given by [13]:

$$k_{UZrH} = 0.0075 T + 17.58, \quad (7)$$

with  $T$  in [°C] and  $k_{UZrH}$  in [W/mK]. The thermal conductivity of the AISI 304 steel cladding is given by [14]:


$$k_{rev} = 3.17 \times 10^{-9} T^3 - 6.67 \times 10^{-6} T^2 + 1.81 \times 10^{-2} T + 14.46, \quad (8)$$

with  $T$  in [°C] and  $k_{rev}$  in [W/mK].

The value of  $R_{gap}$  is the value of the overall resistance of the fuel element ( $R_g$ ) less the values of other component resistance. It is found with the values of  $k_g$  and  $h_{sur}$  obtained previously and with the values of  $k$  for the fuel alloy and for the cladding corrected in function of temperature. The heat transfer coefficient in the gap is:

$$h_{gap} = \frac{2}{r_0} \left( \frac{k_g k_{UZrH} k_{rev}}{k_{UZrH} k_{rev} - k_g k_{rev} - 2k_g k_{UZrH} \ln(r_2 / r_1)} \right) \quad (9)$$


The graph of heat transfer coefficient through the gap is shown in Fig. 4, as a function of the reactor power. This figure also shows three theoretical values recommended by General Atomic for the heat transfer coefficient [2].



**Figure 4. Heat transfer coefficient through the gap as a function of the power and fuel element configuration**

#### 4. FUEL ROD TEMPERATURE PROFILE

From the temperature in the center of the fuel and using the equations of conduction for the fuel element geometry, it is possible to obtain the radial temperature distribution in the fuel element. Figure 5 shows the experimental radial profile of maximum fuel temperature in position B1 and it is compared with the PANTERA code results [15]. The instrumented fuel element was used to measure the fuel temperature at several reactor powers. The results are also shown in Fig. 5.



**Figure 5. Experimental fuel rod radial temperature profile in position B1 at 265 kW and at other reactor powers**

#### 5. CONCLUSION

Subcooled pool boiling occurs above approximately 60 kW on the cladding surface in the central channels of the IPR-R1 TRIGA core. However, the high heat transfer coefficient due to subcooled boiling causes the cladding temperature be quite uniform along most of the active fuel rod region and do not increase very much with the reactor power. The IPR-R1

TRIGA Reactor normally operates in the range from 100 kW until a maximum of 250 kW. On these power levels the heat transfer regime between the clad surface and the coolant is subcooled nucleate boiling in the hottest fuel element. Boiling heat transfer is usually the most efficient heat transfer pattern in nuclear reactors core [6]. Another important aspect of the reactor operation safety is that it is far from the occurrence of critical heat flux [16].

## ACKNOWLEDGMENTS

The authors thank to the operation staff of the IPR-R1 TRIGA Reactor for their help during the experiments.

## REFERENCES

1. Todreas N.E. and Kazimi M.S., *Nuclear Systems I: Thermal Hydraulic Fundamentals*, Hemisphere Publishing Corporation, New York, (1990).
2. General Atomic, Safeguards Summary Report for the New York University TRIGA Mark I Reactor. (GA-9864). San Diego, (1970).
3. Dalle H.M., *Neutronic Calculations of the IPR-R1 TRIGA Reactor with WIMSD4 e CITATION*. M. Sc dissertation, Universidade Federal de Minas Gerais, Belo Horizonte, (in Portuguese), (1999).
4. Dalle H.M., *Neutronic Analyses of the IPR-R1 TRIGA Reactor with 63 Fuel Elements Configuration and Regulating Control Rod in Position F16*, CDTN/CNEN, NI-EC3-01/03, Belo Horizonte, (in Portuguese), (2003).
5. Lamarsh J.R. and Baratta A.J., *Introduction to Nuclear Engineering*, 3<sup>o</sup> ed., Upper Saddle River: Prentice Hall, (2001).
6. Duderstadt J.J and Hamilton L.J.; *Nuclear Reactor Analysis*, John Wiley & Sons, Inc. New York, (1976).
7. Wagner W. and Kruse A., *Properties of Water and Steam – The Industrial Standard IAPWS-IF97 for the Thermodynamics Properties*, Springer, Berlin, (1998).
8. Tong L.S. and Weisman J., *Thermal Analysis of Pressurized Water Reactors*, Third Edition, American Nuclear Society. Illinois, (1996)
9. Mesquita A. Z., *Experimental Investigation on Temperatures Distributions in a Research Nuclear Reactor TRIGA IPR-R1*, Ph.D thesis, Universidade Estadual de Campinas, São Paulo, (in Portuguese), (2005).
10. Glasstone S. and Sesonske A., *Nuclear Reactor Engineering*, 4 ed., Chapman and Hall, New York, NY, (1994).
11. Kreith F. and Bohn M. S., *Principles of Heat Transfer*, 6<sup>th</sup> ed., Brooks/Cole, New York, (2001).
12. Tong L. S. and Tang Y.S, *Boiling Heat Transfer and Two-Phase Flow*, 2<sup>nd</sup>. Ed. Taylor & Francis, Washington, (1997).
13. Simnad M.T., Foushee F.C. and West G.B., *Fuel Elements for Pulsed TRIGA Research Reactors*, Nuclear Technology, 28:31-56. (1976).
14. ASME, *ASME Boiler and Pressure Vessel Code, Section II – Materials, Part D, Properties*”, The American Society of Mechanical Engineers, New York, (1992).
15. Veloso M.A., *Thermal-hydraulic Analyses of the IPR-R1 TRIGA Reactor on 250 kW*, CDTN/CNEN, NI-EC3-05/05, Belo Horizonte, (in Portuguese), (2005).
16. Mesquita A.Z. and Rezende H.C., *Experimental Prediction of the Critical Heat Flux on the IPR-R1 TRIGA Nuclear Reactor. Proceeding of 3<sup>rd</sup> World Triga Users Conference*, Belo Horizonte, August 22 to 25, (2006).